



S.K. FIRE PROTECTION ENGINEERS

Deals in: All Type of Fire Extinguishers & Safety Equipments
Spl. in: Fire Hydrant & Alarm Systems.

MARKET COMMITTEE GAUSHALA ROAD, KARNAL-132001
Email: skfire726@gmail.com

TEST CERTIFICATE

VALID FOR ONE YEAR ONLY

Sr. No. 839

Dated. 24/10/24

1. This is to be certify that under noted chemicals Fire Extinguishers have this day been subject to Hydraulic pressure Test of 250 lbs. per square inch for two and half minutes with following result.

2.	TYPE	D.C.P.	Co2.	W.Co2	AFFF	ABC	No. of Extinguishers
	1					5	5 Nos

3. Individual numbers of Extinguishers which withstand the required test.

(1) ABC = 5 nos

4. Individul numbers of Extinguishers which failed to withstand the required test and there for condemned as being unfit to further use.

N/A

5. Remarks - OK Re-filled on: 24-10-2024
Due on: 23-10-2025

6. M/s. DCDC
RCCMC, KARNAL

For S.K. Fire Protection Engineers

Signature



'जय माता की'

S.K. FIRE PROTECTION ENGINEERS

Deals in : All type of Fire Extinguishers & Safety Equipments
Spl. in : Fire Hydrant & Alarm Systems.

MARKET COMMITTEE GAUSHALA ROAD, KARNAL-132001

Mob. : 99960-25940, 95415-33113 | E-mail : skfire726@gmail.com

Ref. No.....

Date...24/10/24

To,

M/S DC DC

KCCMC, KARNAL

(1) Refilling of ABC type fire extinguisher
= 5 x 400 = 2000

Terms & Conditions

- ① FOR at your site.
- ② GST 18% extra charge.