



AGSS ANALYTICAL AND RESEARCH LAB (P) LTD.

(Accredited as per ISO/IEC 17025 : 2017, Recognised by FSSAI, MoEF&CC and Directorate of Ayush)

C-37/2, 3rd & 4th Floor, Lawrence Road, Industrial Area, Delhi-35

Ph.: 011-45022985, 9311654060

E-mail: agsslabs@gmail.com, support@agsslabs.com Web.: www.agsslabs.com



Certificate No. TC-12115

Format No.: AGSS/QS/F-024

CIN : U73200DL2016PTC300483 GST : 07AAOCA4142Q1Z6

TEST REPORT

Page No.: 1 of 1

Issued to : Gandhi Hospital-Musheerabad DCDC Kidney Care C-185, Mayapuri Industrial Area New Delhi 110064	ULR No. : TC121152400004386F Report No. : AGSS/WT/24040100003 Sample Issue Date : 01/04/2024 Report Issue Date : 09/04/2024
---	--

Name of The Product : Drain Water-7th Floor	Sample Received Date : 01/04/2024
Product Description : Waste Water	Analysis Starting Date : 01/04/2024
Batch No./Lot No. : NA	Analysis Completion Date : 09/04/2024
Date of Manufacturing : Not specified	Date of Sampling : -
Date of Expiry : Not specified	Quantity Received : 1ltr
Packing Condition : Plastic Bottle	Environment Condition : NA
Location : NA	Sampling Method : NA
Sample Received / Collected By : Anil Kumar(Lab Repre.)	Sampling By : NA
Testing Required : Chemical Test	
Others specification : NA	

TEST RESULT


S.No.	Test Parameters	Units	Results	Requirement as per CPCB	Test Method
Chemical Parameters					
1	pH @ 25° C	-	6.76	5.5-9.0	IS:3025(P-11)
2	Biochemical Oxygen Demand 27° C @ 3days	mg/L	99.6	30 Max	IS:3025(P-44)
3	Chemical Oxygen Demand	mg/L	480	250 Max	IS:3025(P-58)
4	Total Suspended Solids	mg/L	95.0	100 Max	IS:3025(P-17)
5	Oil & grease	mg/L	2.0	10 Max	IS:3025(P-39)


Remarks : Any addition to Deviation or exclusions from the method: No , Specific environment condition during sampling: No
I hereby attest to the authenticity/decision (AGSS/QM-QSP/06) of the test report that the data is correct and accurate to the best of my knowledge and that the testing was performed by the procedure described in the SOP/Standard.
I hereby attest that this test was conducted within compliance. The Tested Sample Does Not Conforms as per to as per CPCB with respect to above test only.

End of Report

T/24040100003-1




Chandra Dev Singh
In Charge(Water & Environment)
Checked by


Dr Shival Singh
Director (Technical)
Authorized Signatory



NOTE : (1) The laboratory accepts the responsibility for content of report. (2) The above result pertain only to the sample tested and applicable parameters. (3) Test report shall not be reproduced except in full, without written approval of the laboratory. (4) This test report shall not be reproduced wholly or in part and can not be used as an evidence in the court of law without written approval of M/S AGSS. (5) The sample will be stored up to 21 days from the date of issue of test report.